

3301 NW 55th Street, Ft. Lauderdale, FL 33309 (954-444-3857)

Test Address:

DAY RD RUTLEDGE. GA 30663

Date Collected: Date Received:

February 27, 2017 February 28, 2017

Date Reported:

March 02. 2017

Email:

Phone:

82-3497

Sample Location: KITCHEN & BATHROOM

Lab Sample Number:

3172

CERTIFICATE OF DRINKING WATER ANALYSIS

CONCLUSION: FAIL

All drinking water parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

TEST PARAMETER	RESULTS	ACCEPTABLE RANGE	DETERMINATION
E. coli	ABSENT	NONE MUST BE PRESENT	PASS
Coliform bacteria	PRESENT	NONE MUST BE PRESENT	FAIL
Lead	None Detected	0 to 14.9 ppb	PASS
Nitrate as Nitrogen	2.37 mg/L	0 to 9.9 mg/L	PASS
Nitrite as Nitrogen	None Detected	0 to 1.0 mg/L	PASS

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: http://water.epa.gov/drink/contaminants/index.cfm

John D. Shane Ph.D., Laboratory Director